


Mobile Scaffold Inspection Checklist

Project Name:	Week Ending:						
Scaffold Location / Number:	Complies? Y=yes N=no N/A=not applicable						
Mobile Scaffold Tower							
	Mon	Tue	Wed	Thu	Fri	Sat	Sun
Manufacturer's erection guidelines displayed on scaffold							
Guardrails in place 1m above all decks (including intermediate decks)							
Mid-rails in place on all decks (including intermediate decks)							
Toe-boards in place on all working decks							
Platforms in place at correct height for work to be undertaken							
Hinged cover in place for walk through platforms							
Horizontal braces as per manufacturers guidelines							
Diagonal braces as per manufacturers guidelines							
Plan brace in place							
Castor wheel locks all operational							
Adjustable legs operational and at correct height for location							
Access ladder secured in place to top rung of scaffold							
Outriggers in place (if required) and foot seated on ground							
Work Location							
Is the fall risk over 4 metres?							
4m fall risk scaffold: Erected and checked by licensed scaffolder							
Work to be carried out covered by SWMS signed by scaffold users							
Pre commencement JSA carried out							
Free of other risks that need to be controlled. (Ground slope, wind loading etc)							
4 Metre fall risk							
	<p>Persons using the mobile scaffold must be trained in the safe erection use and dismantling of the scaffold.</p> <p>This checklist must be completed daily by the person using the mobile scaffold and whenever the scaffold is altered or re-assembled in any position.</p> <p>Only mark Y if the relevant item is in place and in sound condition. Any item marked N must be addressed and in place prior to the scaffold tower being used. Details to be recorded in Comments and Actions.</p>						
Comments and Actions:							
Inspection by (Print Name):				Scaffold Certificate Number:			
Position:				Company:			
Signature:				Date:			
DISTRIBUTION: Original Kept on Mobile Scaffold, Copy Project Leader/Site Manager.							
Reference:							